

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1591:222 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243  
Contact: Leon Newsome (941) 739-4276 FAX (941) 739-4334

**DESIGN:** Model SIGA-AB4G smoke detector base with integral audible signal. Model AB4G-SB backbox for use with detector base. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 16-33 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, and UL label.

**APPROVAL:** Listed as a smoke detector base for use with listee's separately listed SIGA series smoke detector heads and fire alarm control units. Refer to listee's Installation Instruction Manual for details.

04-28-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 28, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**